

Tim Jordan  
December 1, 2023

Exeter R6 School District has created a plan to ensure drinking water is safe for students and adults in the school district. It is our goal to comply with RSMO160.077 “Get The Lead Out of School Drinking Water”(2022)

Exeter School is utilizing the Missouri Department of Health and Senior Services as the guide to test the water and communicate results to the community. The state has determined that lead remediation levels of drinking water to be 5 ppb. When a lead sample is detected at or above this level, Exeter Schools will take immediate action to address the source of the lead. It is our goal and responsibility to protect children and staff with safe drinking water.

The plan

- We have created an inventory of all drinking and cooking water outlets in the district.
- Test water outlets that are used for drinking and cooking before August 1,2024.
- This [link](#) will explain the health effects of lead to the public
- Communicate all test results to the community within two weeks of getting results
- Communicate remediation plans if necessary after getting the results.

The safety of students and staff is of utmost importance to Exeter Schools. We will continue to communicate, retest, and remediate based on the results of the water testing results. All testing will be sent to approved testing labs by the state agencies.

Sincerely,

Mr. Tim Jordan  
Superintendent of Schools

Links for Information:

- 1) <https://health.mo.gov/living/environment/lead/publications.php>
- 2) <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>
- 3) <https://revisor.mo.gov/main/OneSection.aspx?section=160.077&srch=y>



Pace Analytical Services, LLC  
2231 W. Altorfer Drive  
Peoria, IL 61615  
(800)752-6651

July 15, 2024

Timothy Jordan  
Exeter R6 School District  
101 Locust Street  
Exeter, MO 65647

RE: Drinking Water Lead

Dear Timothy Jordan:

Please find enclosed the analytical results for the **22** sample(s) the laboratory received on **7/5/24 10:40 am** and logged in under work order **HG00874**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or [lisa.grant@pacelabs.com](mailto:lisa.grant@pacelabs.com).

A handwritten signature in black ink, appearing to read "Chenise Lambert-Sykes".

Chenise Lambert-Sykes  
Project Manager  
(314)432-0550  
[Chenise.Lambert-Sykes@pacelabs.com](mailto:Chenise.Lambert-Sykes@pacelabs.com)



**ANALYTICAL RESULTS**

Sample: HG00874-01  
 Name: 1/Stagnant  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 10:14  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:27	BRS	EPA 200.8 REV 5.4

Sample: HG00874-02  
 Name: 1  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 10:17  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:28	BRS	EPA 200.8 REV 5.4

Sample: HG00874-03  
 Name: 2/Stagnant  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 10:21  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:32	BRS	EPA 200.8 REV 5.4

Sample: HG00874-04  
 Name: 2  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 10:24  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:34	BRS	EPA 200.8 REV 5.4



**ANALYTICAL RESULTS**

Sample: HG00874-05  
 Name: 3/Stagnant  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 10:29  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:35	BRS	EPA 200.8 REV 5.4

Sample: HG00874-06  
 Name: 3  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 10:33  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:37	BRS	EPA 200.8 REV 5.4

Sample: HG00874-07  
 Name: 4/Stagnant  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 10:41  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:41	BRS	EPA 200.8 REV 5.4

Sample: HG00874-08  
 Name: 4  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 10:45  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:42	BRS	EPA 200.8 REV 5.4



**ANALYTICAL RESULTS**

Sample: HG00874-09  
 Name: 5/Stagnant  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 10:51  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:44	BRS	EPA 200.8 REV 5.4

Sample: HG00874-10  
 Name: 5  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 10:55  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:45	BRS	EPA 200.8 REV 5.4

Sample: HG00874-11  
 Name: 6/Stagnant  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 11:01  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:46	BRS	EPA 200.8 REV 5.4

Sample: HG00874-12  
 Name: 6  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 11:05  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:48	BRS	EPA 200.8 REV 5.4



**ANALYTICAL RESULTS**

Sample: HG00874-13  
 Name: 7/Stagnant  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 11:11  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:52	BRS	EPA 200.8 REV 5.4

Sample: HG00874-14  
 Name: 7  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 11:16  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:53	BRS	EPA 200.8 REV 5.4

Sample: HG00874-15  
 Name: 8/Stagnant  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 11:25  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:58	BRS	EPA 200.8 REV 5.4

Sample: HG00874-16  
 Name: 8  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 11:31  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 16:59	BRS	EPA 200.8 REV 5.4



**ANALYTICAL RESULTS**

Sample: HG00874-17  
 Name: 9/Stagnant  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 11:36  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 17:00	BRS	EPA 200.8 REV 5.4

Sample: HG00874-18  
 Name: 9  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 11:46  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 17:02	BRS	EPA 200.8 REV 5.4

Sample: HG00874-19  
 Name: 10/Stagnant  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 11:51  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	1.62	ug/L		07/11/24 11:03	1	1.00	07/11/24 17:03	BRS	EPA 200.8 REV 5.4

Sample: HG00874-20  
 Name: 10  
 Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 11:56  
 Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 17:05	BRS	EPA 200.8 REV 5.4



**ANALYTICAL RESULTS**

Sample: HG00874-21  
Name: 11/Stagnant  
Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 12:01  
Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 17:06	BRS	EPA 200.8 REV 5.4

Sample: HG00874-22  
Name: 11  
Matrix: Drinking Water - Regular Sample

Sampled: 07/01/24 12:05  
Received: 07/05/24 10:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		07/11/24 11:03	1	1.00	07/11/24 17:07	BRS	EPA 200.8 REV 5.4



### NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

\* Not a TNI accredited analyte

### Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Chenise Lambert-Sykes, Project Manager